

NOTES

The SENTRY Guardrail Systems complies with AS1657 : 2018 when installed as per the instructions detailed. These drawings and Instructions must be read in conjunction with the Australian Standards Criteria.

1. Guardrail height is to be 900 - 1000mm from the walking surface or the nosing of a stair tread.
2. Distance between guardrails, intermediate rails or toe-boards shall not be less than 550mm
3. Hand clearance - Min 50mm between the edge of any handrail and adjacent structure.
4. Toe-board - A toe-board shall be installed on the edge of a platform or walkway where there is no permanent structure within 10mm of the edge and from which an object could fall to where persons have access to the area below and to the side of a walkway. Maximum gap between the toe-board and walkway is 10mm.

