

MAINTENANCE CHECKLIST




The checklist below outlines key checking criteria required to ensure the safe use of this system. Any item of concern not shown on the checklist must be noted on the maintenance report and brought to the attention of the workplace manager.

Items ticked PASS - **YES** means they conform with the required checking criteria and are suitable for normal use until the next recertification date. System data plates must be updated showing current check date and next check date.

Item ticked PASS - **NO** means they do not conform to the required checking criteria. These items must be clearly tagged 'Do Not Use' and the required corrective actions put in place. The maintenance report must clearly document all non-conforming criteria.

⚠ This system must be maintained by a competent height safety inspector trained in the safe use and maintenance of this system.

SYSTEM MAINTENANCE CHECKLIST

COMPONENT	INSPECTION CRITERIA	PASS Y / N	CORRECTIVE ACTION	COMPLETION DATE
	Fixings to structure secure (min. 2 fixings to purlin, 8 fixings to roof deck)			
	Screws into structure must be verified by removing and checking if uncertain			
	Fixings to roof deck structure secure			
	No evidence of penetration seal deterioration			
	Ensure eyelet fixing connection to plate is secure, max 5mm play between eyelet and plate.			
	No evidence of eyelet damage or deformation			
	Ensure eyelet rotates freely			
	Data label attached and clearly visible			
	All relevant data filled out including last maintenance date			
	Roof deck quality in good condition i.e. No visible rust or roof deterioration.			

⚠ A record of system maintenance, recertification and repairs must be kept by the workplace manager.