

MAINTENANCE CHECKLIST

The checklist below outlines key checking criteria required to ensure the safe use of this system. Any item of concern not shown on the checklist must be noted on the maintenance report and brought to the attention of the workplace manager.





Items ticked PASS - **YES** means they conform with the required checking criteria and are suitable for normal use until the next recertification date. System data plates must be updated showing current check date and next check date.

Item ticked PASS - **NO** means they do not conform to the required checking criteria. These items must be clearly tagged 'Do Not Use' and the required corrective actions put in place. The maintenance report must clearly document all non-conforming criteria.

⚠ This system must be maintained by a competent height safety inspector trained in the safe use and maintenance of this system.

⚠ installation must be in accordance with checklist provided (page 8).

SYSTEM MAINTENANCE CHECKLIST

COMPONENT	INSPECTION CRITERIA	PASS Y / N	CORRECTIVE ACTION	COMPLETION DATE
	Anchor to be secure with no rotation of eyelet or movement in profiled flange			
	Anchor eyelet to be facing fall direction i.e. parallel with roof sheet direction			
	Data label attached and clearly visible All relevant data filled out including last maintenance date			
	Roof deck and steel support structure quality to be in good condition i.e. no visible rust or damage.			

⚠ A record of system maintenance, recertification and repairs must be kept by the workplace manager.