


MAINTENANCE CHECKLIST









The checklist below outlines key checking criteria required to ensure the safe use of this system. Any item of concern not shown on the checklist must be noted on the maintenance report and brought to the attention of the workplace manager.


Items ticked PASS - YES means they conform with the required checking criteria and are suitable for normal use until the next recertification date. System data plates must be updated showing current check date and next check date.

Item ticked PASS - NO means they do not conform to the required checking criteria. These items must be clearly tagged 'Do Not Use' and the required corrective actions put in place. The maintenance report must clearly document all non-conforming criteria.

 This system must be maintained by a competent height safety inspector trained in the safe use and maintenance of this system.

SYSTEM MAINTENANCE CHECKLIST

COMPONENT	INSPECTION CRITERIA	PASS Y / N	CORRECTIVE ACTION	COMPLETION DATE
	Fixings into roof structure secure - min 2 x 5mm bulb-tite rivets into roof deck			
	EPDM seal between batten and roof deck to seal hole			
	Fixings into roof structure secure - min 2 x 30mm tek screws through fixing disc and into walkway batten			
	Ensure minimum of two fixings through joiner bar into walkway panel			
	No more than +/- 200mm overhang			
	Roof deck quality in good condition i.e. No visible rust or roof deterioration.			

 A record of system maintenance, recertification and repairs must be kept by the workplace manager.